

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

**No. SSAS/20250630023**

**Date :30/06/2025**

It is certified that an inspection team headed by Mr Vishal Doke – Technical Head  
From SSAS Laboratory inspected the VALLEY VIEW HIGH SCHOOL, Sai Baba Nagar, Meeta Nagar,  
Kondhwa, Pune 411048 on 27/06/2025 and found that the VALLEY VIEW HIGH SCHOOL, Sai Baba  
Nagar, Meeta Nagar, Kondhwa, Pune 411048 has safe drinking water facilities for the students and  
members of staff of the institution and is maintaining the hygienic sanitation condition in the school  
building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year

**Signature with Seal:**



**Name**

**: VISHAL DOKE**

**Designation**

**: Technical Head**

**(SSAS Laboratory, NABL Certificate No : TC15217)**

**To**

VALLEY VIEW HIGH SCHOOL,

Sai Baba Nagar, Meeta Nagar, Kondhwa, Pune 411048

**(Name & Address of the Institution)**



# SSAS LABORATORY

[FORMERLY SHREE SIDDHIVINAYAK AQUA SOLUTION LLP]



TC-15217

NABL ACCREDITED LABORATORY

## TEST REPORT

Report No/ULR No : TC152172500000509F Sample Code No : SSAS/2025/06/509  
Sample Receipt Date : 27.06.2025 Sample Description : Water  
Analysis Start Date : 27.06.2025 to 30.06.2025 Sample Condition : Satisfactory  
Date of Report Issue : 30.06.2025 Sample Type & Qty : Water Sample, 1 lit  
Sample Marked As : Drinking Water

### Issued to: VALLEY VIEW HIGH SCHOOL

Sai Baba Nagar, Meeta Nagar, Kondhwa, Pune 411048

Sl. No	PARAMETER TESTED	UNITS	RESULT	IS: 10500-2012 (Second Revision)	TEST METHOD
PHYSICO-CHEMICAL				Requirement (Acceptable Limit)	
1.	Odour	-	Agreeable	Agreeable	IS: 3025 Part-05, 2018
2.	Turbidity	NTU	< 0.1	Max 1	IS: 3025 Part-10, 2023
3.	pH value	-	7.25	6.5-8.5	IS: 3025 Part-11, 2022
4.	Total Dissolved Solids	mg/l	42	Max 500	IS: 3025 Part-16, 2023
5.	Total Hardness as CaCO <sub>3</sub>	mg/l	20.6	Max 200	IS: 3025 Part-21, 2009
6.	Calcium as Ca <sup>++</sup>	mg/l	9.8	Max 75	IS: 3025 Part-40, 1991
7.	Magnesium as Mg <sup>++</sup>	mg/l	2.5	Max 30	IS: 3025 Part-46, 2023
8.	Total Alkalinity as CaCO <sub>3</sub>	mg/l	12.3	Max 200	IS: 3025 Part- 23, 2023
9.	Chloride as Cl <sup>-</sup>	mg/l	6.7	Max 250	IS: 3025 Part- 32, 1988
10.	Free Residual Chlorine	mg/l	< 0.2	0.2	IS: 3025 Part - 26, 2021
11.	Sulphate as SO <sub>4</sub>	mg/l	< 0.1	Max 200	IS: 3025 Part- 32, 1986



+91 9561889433



www.ssaslab.com  
contact@ssaslab.com



Shree Siddhivinayak, Raj Vihar Society  
Undri, Pune 411060





# SSAS LABORATORY

[FORMERLY SHREE SIDDHIVINAYAK AQUA SOLUTION LLP]

NABL ACCREDITED LABORATORY

## TEST REPORT

Report No/ULR No : SSAS20250626509 Sample Code No : SSAS/2025/06/509  
Sample Receipt Date : 27.06.2025 Sample Description : Water  
Analysis Start Date : 27.06.2025 to 30.06.2025 Sample Condition : Satisfactory  
Date of Report Issue : 30.06.2025 Sample Type & Qty : Water Sample, 1 lit  
Sample Marked As : Drinking Water

Sr. No	Parameters Tested	Units	Results	IS: 10500-2012 (Second Revision)	Test Method
				Requirement (Acceptable Limits)	
BACTERIOLOGICAL					
12	Total Coliform (MPN/100ml).	-	Not Detected	Shall not be detectable in any 100 ml sample	IS: 1622, 1981
13	Faecal Coliform (MPN/100ml)	-	Not Detected	Shall not be detectable in any 100 ml sample	IS: 1622, 1981
14	E. coli in 100 ml of sample	-	Absent	Shall not be detectable in any 100 ml sample	IS: 1622, 1981

**Remarks:** 1) The above water sample Fit For Drinking Purpose to IS: 10500-2012 (Second Revision) Drinking Water Specification with respect to the test conducted.  
2) The results relate to parameters tested.

**Note:**

- # To be applicable only when water is chlorinated. Minimum 0.2 mg/l
- Test results are applicable to the sample/s tested as per Job ID only.
- Contents of this report are meant for your guidance & should not be used for advertisement, evidence or litigation.
- This report, shall not be reproduce in full or part, shall not be published, advertised, without the written approval of SSAS Laboratory.
- Total Liability of our Institution is limited to the Invoice Amount / Testing Charges.
- SSAS Laboratories is not responsible for the authenticity of photocopied or scanned reports.
- Subject to Pune Jurisdiction



Review By

Mr Dattatray Doke  
QM

Authorised Signatory

Mr Vishal D  
TM



+91 9561889433



www.ssaslab.com  
contact@ssaslab.com



Shree Siddhivinayak, Raj Vihar Society  
Undri, Pune 411060